


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 537

Dated: 17/03/26

It is certified that an inspection team headed by Sh. Kulwant Singh, Assistant Engineer, Water Supply and Sanitation sub division Bassi Pathana at Fatehgarh Sahib inspected the S.T.S. PUBLIC SR. SEC. SCHOOL, Nandpur Kalour, Fatehgarh Sahib on 11/03/2026 and as per water sample reports, produced by school authorities regarding quality of water, before the team, the S.T.S. PUBLIC SR. SEC. SCHOOL, Nandpur Kalour, Fatehgarh Sahib has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus.

The Certificate is valid up to 31.03.2027.


Sub Divisional Engineer,
Water Supply and Sanitation Sub Division,
Bassi Pathana at Fatehgarh Sahib.

DISTRICT WATER TESTING LABORATORY, FATEHGARH SAHIB

Water Supply & Sanitation Division, Opposite DC Residence, Fatehgarh Sahib

dwtlfgs@gmail.com

To,

Principal,..
S.T.S. Public Sen.SEC.School, Nandpur Kalour, Fatehgarh Sahib


No.: DWTLFGS/2526/00297 Dated : 12/03/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 754 Dated: 06/03/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 10/03/2026. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Fatehgarh Sahib

D/A : Test Report



**Authorized Signatory
For, District Water Testing Laboratory
Fatehgarh Sahib**

DISTRICT WATER TESTING LABORATORY, FATEHGARH SAHIB

Water Supply & Sanitation Division, Opposite DC Residence, Fatehgarh Sahib

dwtlfgs@gmail.com



TC-12711

TEST REPORT							
Name & Address of Customer : Principal,... S.T.S. Public Sen.SEC.School, Nandpur Kalour,Fatehgarh Sahib			Customer Reference No.	No : 754 Dated : 06/03/2026			
			Sample Submitted by				
			Date of Sample Receipt	10/03/2026			
			Analysis Starting Date	10/03/2026			
			Analysis completion Date	11/03/2026			
Discipline : Chemical Testing			Group: Water				
ULR No.:	TC127112600000037F		Sample Type :	Water			
Test Report No.:	DWTLFGS/2526/00297		Date of Issue :	12/03/2026			
Registration no.:	DWTLFGS/REG2526/02125		Condition of Sample :	Unsealed			
Collection Point:	Private Submersible		Quantity/Type of Bottle:	500 ml / Amber Colored Glass Bottle			
Scheme/Source:	Not Mentioned(Not Mentioned)		Location/Depth :	S.T.S. Public Sen.SEC.School, Nandpur Kalour,Fatehgarh Sahib / NA			
Village :	Nandpur		Habitation :	Nandpur			
Block:	Bassi Pathana		District :	Fatehgarh Sahib			
Latitude :	Not Mentioned		Longitude:	Not Mentioned			
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :	
			Acceptable Limit	Permissible Limit			
1	pH	7.86	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method	
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method	
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)	
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)	
5	TDS	404	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method	
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method	
7	T. Alkalinity(CaCO ₃)	276	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method	
8	T. Hardness(CaCO ₃)	252	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method	
9	Calcium(Ca)	21	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method	
10	Magnesium(Mg)	49	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method	
11	Chloride(Cl)	16	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method	

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Sh. Brij Bhushan
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory
Fatehgarh Sahib

----- End of the Test Report -----